

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014684-R5  
DATE: 02/12/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: Builders First  
CODE: 2621-1  
REVISION DATE: 09/07/2023  
EXPIRATION DATE: 02/28/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Builders First Source Corporation</b> <b>7700 Caldwell Drive</b> <b>Harrisburg, NC 28075</b>	<b>Crest Doors 20 Minute Positive Pressure</b> <b>Particleboard Core/Wood Veneer</b> <b>Side-Hinged Door Assembly</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single & Double Swing Only  <b>Single Maximum Size: 4'0" x 9'0"</b> <b>Double Maximum Size: 8'0" x 9'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UBC-7-2-97</b> <b>UL 10C (1998)(2009)</b> <b>NFPA 252 (1995)(2008)</b>	<b>20 Minute-Positive Pressure w/o Hose Stream</b> <b>Category A Door-No Additional Edge Seal Required</b> <b>Category B Door-Additional Edge Seal Required</b> <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Warnock Hershey Test Report No: WHI-495-1367</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**

**Hayes, VA 23072**

**Tel: (804) 684-5124**

**[nami@namiinc.com](mailto:nami@namiinc.com)**

**NOPC 03/30/2023**