

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015095-R1
DATE: 11/30/2020
CERTIFICATION PROGRAM: Fire
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 06/23/2021
EXPIRATION DATE: 01/31/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	20-Minute Conmore Routed Particleboard Core Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2001) CAN/ULC S104 (1985)	20 Minute-Positive Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 3176461MID-003, 3169881, G100027980, G100418906, G103408699 NAMI Waiver of Retest: W-1998

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122