

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015102-R2  
DATE: 12/31/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 10/31/2023  
EXPIRATION DATE: 12/31/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b>  <b>3737 Lakeport Boulevard</b>  <b>Klamath Falls, OR 97601</b>	<b>20-90 Minute Foam-Filled Steel Fire Door</b>  <b>(Hollow Metal/24 or 26 Gauge/Flush or Embossed)</b>  Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 6'0" x 8'0"</b> <b>(Must refer to listing for size/rating limitations)</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10C (2009/2016)</b> <b>UL 10B (2009)</b> <b>UBC Standard 7-2 (1994/1997)</b> <b>CAN/ULC S104 (2010/2015)</b>	<b>90 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> (26 Gauge Skin - 3'0" x 7'0" Maximum Size) <b>Category B - Additional Edge-Sealing</b> <b>System Required</b>

TEST REPORT
<b>Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001</b> <b>NAMI Waiver of Retest: W-1998/W-2028/W-2063/W-2090</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway  
Hayes, VA 23072**

**Tel: (804) 684-5124/ [nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC-03/30/2023