

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015131
DATE: 12/21/2020
CERTIFICATION PROGRAM: Man Housing
COMPANY: Wausau Supply
CODE: 1644-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wausau Supply Company, Inc. 8011 Technology Drive Schofield, WI 54476	Plastpro Opaque Fiberglass In-Swing Side Hinged Door Configuration: XX Frame: W-1880mm(74") H-2083mm(82") Panel: W-908mm(35.75") H-2013mm(79.25") STP: Pos+2777 Pa (58 psf) Neg-2777 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.405	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01391950
Expiration Date: December 31, 2024

Administrator's Signature: _____


NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122