

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015135.01  
DATE: 02/06/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Four Seasons  
CODE: 1812-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Four Seasons Solar Products, LLC</b> <b>5005 Veterans Memorial Highway</b> <b>Holbrook, NY 11741</b>	<b>Series "FSSW8000"</b> <b>Vinyl Horizontal Sliding Window</b> <b>(w/Exterior Sash Clips)</b>  Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1803mm(71") H-1499mm(59") Sash: W-899mm(35.38") H-1419m(55.88") DLO: W-803mm(31.63") H-1324mm(52.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG40 1803 x 1499 (71 x 59)-HS</b> <b>Design Pressure: ±1920 Pa (±40 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo Architectural Product Testing, Inc.  
Report No: 2478.02-109-12-R2  
Expiration Date: November 30, 2024

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122