

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015135.02
DATE: 04/20/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Four Seasons
CODE: 1812-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Four Seasons Solar Products, LLC 5005 Veterans Memorial Highway Holbrook, NY 11741	Series "FSSW8000" Vinyl Horizontal Sliding Window (w/Exterior Sash Clips) Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1600mm(63") H-1499mm(59") Sash: W-797mm(31.38") H-1419m(55.88") DLO: W-702mm(27.63") H-1324mm(52.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 1600 x 1499* (63 x 59*)-HS Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo Architectural Product Testing, Inc.
Report No: 2478.02-109-12-R3
Expiration Date: **March 31, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122