

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015136-R4
DATE: 01/05/2021
CERTIFICATION PROGRAM: Fire
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 10/31/2023
EXPIRATION DATE: 01/31/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	“Madison/Monroe/Craftsman/Birkdale” Molded Panel Composite Fire Doors Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-11/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) UL 10C (2009/2015/2016) UL 10B (2009/2015) CAN/ULC S104 (2015)	20 Minute-Positive or Neutral Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 2192291COQ-005, 101070204COQ-001B Intertek EEV No: 100921055COQ-001, 103667744MID-001, 104106427MID-001, 1029627719MID-001 NAMI Waiver of Retest: W-1998/W-2028/W-2063/W-2090

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com