

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015146.01
DATE: 01/25/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Dunbarton
CODE: 1319-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dunbarton Corporation 555 Benton Industrial Road Camden, TN 38320	"Achiever" Steel Frame w/Glazed Inswing Fiberglass Door w/Sidelite Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-1899mm(74.75") H-2076mm(81.75") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-530mm(20.88") H-1597mm(62.88")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sections)	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01093193
Expiration Date: **December 31, 2024**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shelby", is written over the signature line.

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122