

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015149
DATE: 01/26/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "ICMG III" Insulated Glass Skylight w/Laminated Glass (Impact) Configuration: O Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray Butacite PVB Interlayer/1/8" Annealed Glass Frame: W-1295mm(51") H-1295mm(51") DLO: W-1162mm(45.75") H-1162mm(45.75")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4188-01
Expiration Date: August 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122