

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015150-R1  
DATE: 01/26/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Sun-Tek  
CODE: 225-1  
REVISION DATE: 05/08/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sun-Tek Manufacturing, Inc.</b> <b>10303 General Drive</b> <b>Orlando, FL 32824</b>	<b>Series "CMG III"</b> <b>Insulated Glass Skylight</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-1295mm(51") H-1295mm(51") DLO: W-1162mm(45.75") H-1162mm(45.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class SKG-PG90 1295 x 1295 (51 x 51)</b> <b>Design Pressure: ±4320 Pa (90 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4188-2  
Expiration Date: August 31, 2025

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023