

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015153
DATE: 01/26/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Optimum
CODE: 1742-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Optimum Window Manufacturing Corporation 28 Canal Street Ellenville, NY 12428	Series "RTS-430i" Steel Awning Window Configuration: X Glazing: IG-3/16" Heat Strengthened Glass/0.090" SGP Interlayer/3/16" Heat Strengthened Glass/1/4" Tempered Glass Frame: W-1372mm(54") H-1070mm(42.13") DLO: W-1262mm(49.69") H-929mm(36.56")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-OPM-18-002
Expiration Date: August 31, 2024

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122