

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015157.03
DATE: 02/10/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sunrise Win.
CODE: 2483-1

To verify that the “Notice of Product Certification” is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Sunrise Windows, LTD 200 Enterprise Drive Temperance, MI 48182</p>	<p style="text-align: center;">Series “Coastal Performance” Vinyl Sliding Glass Door (Impact)</p> <p style="text-align: center;">Configuration: XO Glazing: IG - 5/32" Tempered Glass/5/32" Annealed Glass/0.090" SentryGlas PVB Interlayer/5/32" Annealed Glass</p> <p>Frame: W-2438mm(96") H-2438mm(96") Panel: W-1235mm(48.63") H-2330mm(91.75") DLO: W-1057mm(41.63") H-2172mm(85.5")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a ASTM E1996-14a</p>	<p style="text-align: center;">Class LC-PG50 2438 x 2438 (96 x 96)-SD Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Wind Zone 3 - Missile Level D</p>

Product Tested By: Testing Evaluation Laboratories
 Report No: TEL 15503186/TEL 15503191
 Expiration Date: **November 30, 2024**

A handwritten signature in black ink, appearing to be 'SHE'.

Administrator’s Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122