

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015157.04
DATE: 02/10/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sunrise Win.
CODE: 2483-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunrise Windows, LTD 200 Enterprise Drive Temperance, MI 48182	Series "Coastal Performance" Vinyl Sliding Glass Door (Impact) Configuration: XO Glazing: IG - 5/32" Tempered Glass/5/32" Annealed Glass/0.090" Saflex Storm PET Interlayer/5/32" Annealed Glass Frame: W-2438mm(96") H-2438mm(96") Panel: W-1235mm(48.63") H-2330mm(91.75") DLO: W-1057mm(41.63") H-2172mm(85.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a ASTM E1996-14a	Class LC-PG50 2438 x 2438 (96 x 96)-SD Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Wind Zone 3 - Missile Level D

Product Tested By: Testing Evaluation Laboratories
Report No: TEL 15503188/TEL 15503191
Expiration Date: November 30, 2024

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122