

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015157.05  
**DATE:** 02/10/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Sunrise Win.  
**CODE:** 2483-1

To verify that the “Notice of Product Certification” is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Sunrise Windows, LTD</b></p> <p><b>200 Enterprise Drive</b></p> <p><b>Temperance, MI 48182</b></p>	<p style="text-align: center;"><b>Series “Coastal Performance”</b></p> <p style="text-align: center;"><b>Vinyl Sliding Glass Door</b></p> <p style="text-align: center;"><b>(Impact)</b></p> <p style="text-align: center;">Configuration: XO                      Glazing: IG - 5/32" Tempered Glass/5/32" Annealed Glass/0.090" Saflex Storm PET Interlayer/5/32" Annealed Glass</p> <p>Frame:    W-2438mm(96")        H-2438mm(96")</p> <p>Panel:     W-1235mm(48.63")    H-2330mm(91.75")</p> <p>DLO:       W-1057mm(41.63")    H-2172mm(85.5")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"><b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b></p> <p style="text-align: center;"><b>ASTM E1886-13a</b></p> <p style="text-align: center;"><b>ASTM E1996-14a</b></p>	<p style="text-align: center;"><b>Class LC-PG50 2438 x 2438 (96 x 96)-SD</b></p> <p style="text-align: center;"><b>Design Pressure: 2400 Pa (50 psf)</b></p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</p> <p style="text-align: center;"><b>Wind Zone 3 - Missile Level D</b></p>

Product Tested By: Testing Evaluation Laboratories  
 Report No: TEL 15503189/TEL 15503191  
 Expiration Date: **November 30, 2024**

Administrator’s Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122