

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015157  
DATE: 02/10/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Sunrise Win.  
CODE: 2483-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sunrise Windows, LTD</b> <b>200 Enterprise Drive</b> <b>Temperance, MI 48182</b>	<b>Series "Coastal Performance"</b> <b>Vinyl Sliding Glass Door</b> <b>(Impact)</b>  Configuration: XO Glazing: IG - 5/32" Tempered Glass/5/32" Annealed Glass/0.090" Trosifol PVB Interlayer/5/32" Annealed Glass  Frame: W-2400mm(94.50") H-2019mm(79.50") Panel: W-1214mm(47.81") H-1911mm(75.25") DLO: W-1038mm(40.88") H-1754mm(69.06")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Class LC-PG50 2413 x 2032* (95 x 80*)-SD</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Testing Evaluation Laboratories  
Report No: TEL 15503185/TEL 15503191  
Expiration Date: November 30, 2024

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'M.D.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122