

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015158.02-R2
DATE: 02/11/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 03/27/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	Series "25 Stormforce Double Hung" Aluminum Clad Wood Transom Configuration: O Glazing: IG- Ext. 3/16" Annealed Glass/0.090 SGP Dupont Interlayer/3/16" Annealed Glass/Int. 5/32" Annealed Glass Frame: W-2353mm(92.63") H-1219mm(48") DLO: W-2181mm(85.88") H-1048mm(41.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05 ASTM E1996-05 TAS 201/202/203-94	Class LC-PG70 2353 x 1219 (92 x 48)-TR TR-LC70 2353 x 1219 (92 x 48) Design Pressure: ±3360 Pa (70 psf) Positive Design Pressure: 3360 Pa (70 psf) Negative Design Pressure: 4080 Pa (85 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.50 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: A6347.13-201-18/A6347.01-201-18/A6347.02-201-18/W-2116
Expiration Date: **February 28, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023