

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015162.04
DATE: 02/18/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sunrise Win.
CODE: 2483-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunrise Windows, LTD 200 Enterprise Drive Temperance, MI 48182	Series "Restorations" Vinyl Fixed Window (Non-Impact) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1503mm(59.19") H-1607mm(63.25") DLO: W-1427mm(56.19") H-1530mm(60.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 1499 x 1600 (59 x 63)-FW Design Pressure: ±2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 575 Pa (12 psf)

Product Tested By: Testing Evaluation Laboratories
Report No: TEL 15503117
Expiration Date: August 31, 2024

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122