

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015163
DATE: 02/23/2021
CERTIFICATION PROGRAM: Structural
COMPANY: EMC Windows
CODE: 2044-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>EMC Windows and Doors, LLC</p> <p>3695 Northwest 74th Street</p> <p>Hialeah, FL 33147</p>	<p style="text-align: center;">Series "4500"</p> <p style="text-align: center;">Aluminum Fixed Window Assembly</p> <p style="text-align: center;">Configuration: O/OOO Glazing: Glass Type A Laminate-1/4" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/Glass Type B Laminate-1/4" Heat Strengthened Glass or 1/4" Heat Strengthened Glass/0.090" PVB Interlayer by DuPont/1/4" Heat Strengthened Glass</p> <p>Frame: W-4629mm(182.25") H-3048mm(120")</p> <p>Glass Type A DLO: W-1467mm(57.75") H-2934mm(115.5")</p> <p>Glass Type B DLO: W-1467mm(57.75") H-1438mm(56.63")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202/203-94</p>	<p>Design Pressure: 3591 Pa (75 psf) Negative Design Pressure: 3830 Pa (80 psf) Large Missile Impact Rated</p>

Product Tested By: Blackwater Testing, Inc.
 Report No: BT-AT-14-001A
 Expiration Date: **February 28, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122