

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI015176
DATE:	03/18/2021
CERTIFICATION PROGRAM:	Fire
COMPANY:	BMC Millwork
CODE:	1665-1
EXPIRATION DATE:	03/31/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>BMC Millwork Corporation</p> <p>399 Northpoint Parkway</p> <p>Acworth, GA 30102</p>	<p style="text-align: center;">20 Minute Positive Pressure</p> <p style="text-align: center;">Molded Simulated Panel Side-Hinged</p> <p style="text-align: center;">Side-Hinged Door Assembly</p> <p style="text-align: center; font-size: small;">Manufacturer Specific Fire Doors for Single Swing or Standard Pairs Installation in 20 Minute Locations</p> <p style="text-align: center; font-size: small;">1/2" Minimum Latch Throw Single Swing or Standard Pairs Only</p> <p style="text-align: center; font-size: small;">Single Swing Maximum Size: 3'0" x 8'0" Standard Pairs Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>NFPA 252 (1999)</p> <p>UL 10(b) (2009)</p> <p>CAN4-S104 (1985)(2010)</p> <p>UL 10(c) (2009)</p>	<p style="text-align: center;">20 Minute-Positive Pressure</p> <p style="text-align: center;">With Hose Stream</p> <p style="text-align: center;">Category B Door-Additional Edge Seal</p> <p style="text-align: center;">Required</p> <p style="text-align: center;">For Use in Category C Frame</p> <p style="text-align: center; font-size: small;">(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</p>

TEST REPORT
<p>Intertek Test Report No: 3192291COQ-005, 100211525COQ-001, 100553244COQ-002, 100581395MID-001, 101432263COQ</p>

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122