

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015185
DATE: 03/18/2021
CERTIFICATION PROGRAM: Fire
COMPANY: BMC Millwork
CODE: 1665-1
EXPIRATION DATE: 03/31/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BMC Millwork Corporation 399 Northpoint Parkway Acworth, GA 30102	20-Minute Single Swing Wood Door Frame Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'1-3/8" x 7'2" Minimum Thickness: 3-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1995/2008) UL 10(b) (1997/2009) CAN/ULC S104 (1985/2010)	20 Minute-Neutral Pressure With Hose Stream Category C- Proprietary Frame

TEST REPORT
Warnock Hershey Test Report No: WHI-3010, WHI-495-1094, WHI-495-1525

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124 Fax: (804) 684-5122