

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015186  
**DATE:** 03/18/2021  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** BMC Millwork  
**CODE:** 1665-1  
**EXPIRATION DATE:** 03/31/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>BMC Millwork Corporation</b> <b>399 Northpoint Parkway</b> <b>Acworth, GA 30102</b>	<b>20-Minute</b> <b>Single or Double Swing Wood Door Frame</b>  Manufacture Specific Fire Door Frames for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 6'2-3/8" x 8'1-3/16"</b> <b>Minimum Thickness: 4-1/2"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1995/2008)</b> <b>UL 10(b) (1997/2009)</b> <b>UL 10(c) (2009)</b> <b>CAN/ULC S104 (1985/2010)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category C- Proprietary Frame</b>

TEST REPORT
<b>Warnock Hershey Test Report No: WHI-3010, WHI-495-1094, WHI-495-1525</b>

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124 Fax: (804) 684-5122