

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015190  
DATE: 03/18/2021  
CERTIFICATION PROGRAM: Fire  
COMPANY: BMC Millwork  
CODE: 1665-1  
EXPIRATION DATE: 03/31/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>BMC Millwork Corporation</b> <b>399 Northpoint Parkway</b> <b>Acworth, GA 30102</b>	<b>"Warm Springs 90-Minute"</b> <b>Flush Panel Composite Fire Doors</b> Manufacturer Specific Fire Doors for Single or Double Swing Installation in 90 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 8'0" x 8'0"</b> <b>(Must refer to listing for size/rating limitations)</b> <b>Minimum Thickness: 1-11/16"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012/2017)</b> <b>UL 10C (2009/2016)</b> <b>CAN/ULC S104 (2010/2015)</b>	<b>90 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category A - No Additional Edge-Sealing</b> <b>System Required</b> Temperature Rise @ 30 Min: 250° F Max (Where lites do not exceed 100 in <sup>2</sup> )

TEST REPORT
<b>Intertek Test Report No: 104142512COQ-006</b> <b>NAMI Waiver of Retest: W-1985/W-1989</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122