

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015193  
DATE: 03/25/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Heister  
CODE: 2310-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Heister House Millworks, Inc.</b> <b>1937 Troup Valley Road</b> <b>Mt. Pleasant Mills, PA 17853</b>	<b>Series "Steel Opaque Side-Hinged</b> <b>Entry Door w/Sidelites</b> <b>w/Wood or Composite Frame</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1718mm(67.63") H-2084mm(82.05") Panel: W-914mm(36") H-2013mm(79.25") Sidelite: W-354mm(13.94") H-2013mm(79.25") STP: Pos+58.0 psf Neg-58.0 psf

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.02-95(02)</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: Architectural Testing, Inc.  
Report No: A4929.01-501-47/W-1467  
Expiration Date: March 31, 2023

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/  
Fax: (804) 684-5122