

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015200
DATE: 04/07/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Dealers Supply
CODE: 786-1
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dealers Supply & Lumber Company 105 Airport Road Greenville, SC 29606	Rogue Valley's 20 Minute 4-13/16" Wood Frame w/Hose Stream Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Maximum Frame Size: 84" x 96" Minimum Width: 4-13/16" Nominal Thickness: 9/16"

SPECIFICATION	PRODUCT RATING
UBC 7-2 (1997) NFPA 252 (2008) UL 10(c) (2001)(2009) UL 10 (b) (2008)(2009) CAN4 S104 (1980(R1985))(2010)	20 Minute-With Hose Stream Positive Pressure/Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No: 3049231

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122

