

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015203  
DATE: 04/07/2021  
CERTIFICATION PROGRAM: Fire  
COMPANY: Dealers Supply  
CODE: 786-1  
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Dealers Supply &amp; Lumber Company</b><br><b>105 Airport Road</b><br><b>Greenville, SC 29606</b> | <b>Rogue Valley 20 Minute</b><br><b>Positive/Neutral Pressure Panel-Type</b><br><b>MDF Side-Hinged Door Assembly</b><br><br>Manufacturer Specific Fire Doors for Single & Double Swing<br>Installation in 20 Minute Locations<br><br>1/2" Minimum Latch Throw<br>Single & Double Swing Only<br><br><b>Single Maximum Size: 3'6" x 8'0"</b><br><b>Double Maximum Size: 7'0" x 8'0"</b><br><b>Minimum Thickness: 1-3/4"</b> |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| <b>UBC-7-2-94</b><br><b>UL 10B (1997)(2009)</b><br><b>UL 10C(2009)</b><br><b>NFPA 252 (2003)(2012)</b> | <b>20 Minute-Positive Pressure w/o Hose Stream</b><br><b>20 Minute-Neutral Pressure w/o Hose Stream</b><br><b>Category A Door-No Additional Edge Seal Required</b><br><b>For Use in Category C Frame</b><br><small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small> |

| TEST REPORT                                      |
|--|
| <b>Intertek Test Report No: 3049231/3049231a</b> |

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122