

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015217-R3
DATE: 04/16/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Builders First
CODE: 2621-1
REVISION DATE: 09/07/2023
EXPIRATION DATE: 04/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Builders First Source Corporation 7700 Caldwell Drive Harrisburg, NC 28075	Plastpro 90 Minute Positive Pressure Fire Door Assemblies w/Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 90 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 4'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999)/UL 10C (2001)/ UL 10B (1997) UBC 7-2 (1994) CAN4 S104 (1985)	90 Minute-Positive Pressure With Hose Stream Category B - Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 3058118-02, 3058118-01

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com