

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015222-R1
DATE: 04/19/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9050" Vinyl Horizontal Sliding Window (Fin or Flange Installation) Configuration: XOX Glazing: IG-3/16" Annealed Glass/3/16" Annealed Glass/0.090" Saflex PVB Interlayer/3/16" Annealed Glass Frame: W-2845mm(112") H-1626mm(64") Vent: W-718mm(28.5") H-1543mm(60.88") DLO: W-1321mm(52.56") H-1505mm(60.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-12/13a ASTM E1996-12a/14a TAS 201/202/203-94	Class LC-PG60 2845 x 1626 (112 x 64)-HS Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 210-4206-3/NCTL 210-4206-3A
Expiration Date: **February 28, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023