

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015223-R1  
**DATE:** 04/19/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Shwinco  
**CODE:** 1972-1  
**REVISION DATE:** 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Shwinco Architectural Products, LLC</b></p> <p><b>171 Jet Services Way</b></p> <p><b>Dothan, AL 36303</b></p>	<p style="text-align: center;"><b>Series "9800"</b></p> <p style="text-align: center;"><b>Vinyl Side-Hinged Door Assembly</b></p> <p style="text-align: center;">Configuration: XX                      Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090" Eastman Chemical PVB Interlayer/1/8" Annealed Glass</p> <p>Frame:   W-1880mm(74")      H-2083mm(82")</p> <p>Vent:     W-895mm(35.25")    H-2021mm(79.56")</p> <p>DLO:     W-619mm(24.38")     H-1745mm(68.69")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b></p> <p><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b></p> <p style="text-align: center;"><b>ASTM E1886-05</b></p> <p style="text-align: center;"><b>ASTM E1996-05/09</b></p> <p style="text-align: center;"><b>TAS 201/202/203-94</b></p>	<p><b>Class LC-PG50 1880 x 2083 (74 x 82)-SHD</b></p> <p style="text-align: center;"><b>Design Pressure: ±2400 Pa (50 psf)</b></p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)</p> <p style="text-align: center;"><b>Wind Zone 4-Missile Level D</b></p> <p style="text-align: center;"><b>Large Missile Impact Rated</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL 210-4199-02A/NCTL 210-4199-2  
 Expiration Date: **December 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023