

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015228-R1  
**DATE:** 04/22/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** MP Windows  
**CODE:** 2744-1  
**REVISION DATE:** 01/21/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>MP Windows, Inc</b>  <b>407 River Heights Circle</b>  <b>Anderson, SC 29621</b></p>	<p style="text-align: center;"><b>Series "Impact MP-SH100" Aluminum Thermally-Broken Single Hung Window w/Sill Riser</b></p> <p style="text-align: center;">Configuration: O/X                      Glazing: IG-1/4" Tempered Glass/3/16" Annealed Glass/0.090" Trosifol Interlayer by Kuraray/3/16" Annealed Glass</p> <p>Frame:    W-1349mm(53.13")    H-1981mm(78")                      Sash::    W-1187mm(46.75")    H-922mm(36.29")                      DLO:      W-1072mm(42.2")      H-813mm(32")</p>

SPECIFICATION	PRODUCT RATING
<p><b>AAMA 506-16</b>  <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>  <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>  <b>ASTM E1886-12/13a</b>  <b>ASTM E1996-12a/14a</b></p>	<p><b>Class LC-PG55 1349 x 1981 (53 x 78)-H</b>  <b>Design Pressure: ±2640 Pa (±55 psf)</b>                      Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf)  <b>Large Missile Impact Rated</b>  <b>Wind Zone 3 - Missile Level D</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-210-4209-1  
 Expiration Date: **March 31, 2029**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023