

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015229-R1
DATE: 04/26/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303 | Series "9000" Vinyl Single Hung Window (Flange Installation) Configuration: O/X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1346mm(53") H-2438mm(96") Vent: W-1270mm(50") H-1210mm(47.63") DLO: W-1245mm(49") H-1111mm(47.63") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05 ASTM E1996-05/09 TAS 201/202/203-94 | Class LC-PG60 1346 x 2439 (53 x 96)-H Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 210-4195-03A/NCTL 210-4195-03
Expiration Date: October 31, 2026

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023