

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015248-R1  
**DATE:** 04/28/2021  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** SGM Door  
**CODE:** 2743-1  
**REVISION DATE:** 05/07/2025  
**EXPIRATION DATE:** 04/30/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>SGM Doors and Trim, LLC</b> <b>11500 Main Street, Suite 118</b> <b>Houston, TX 77025</b>	<b>Jeld Wen Premium 20 Minute Neutral Pressure Fiberglass Side-Hinged Door Assemblies</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing and Pairs Allowed  <b>Single Swing Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>  <b>Pairs Maximum Size: 6'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10B (2008/2009)</b> <b>CAN/ULC S104 (2010)</b>	<b>20 Minute-Neutral Pressure With Hose Stream</b> <b>Category B - Additional Edge Sealing Required</b>

TEST REPORT
Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)