

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015256
DATE: 04/28/2021
CERTIFICATION PROGRAM: Fire
COMPANY: SGM Door
CODE: 2743-1
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
SGM Doors and Trim, LLC 14625 Minetta Street, Bldg B Houston, TX 77035	20-90 Minute Foam-Filled Steel Fire Door (Hollow Metal/24 or 26 Gauge/Flush or Embossed) Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 6'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10C (2009/2016) UL 10B (2009) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010/2015)	90 Minute-Neutral/Positive Pressure Without Hose Stream 20 Minute-Positive Pressure With Hose Stream (26 Gauge Skin - 3'0" x 7'0" Maximum Size) Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122