

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015262  
DATE: 04/28/2021  
CERTIFICATION PROGRAM: Fire  
COMPANY: SGM Door  
CODE: 2743-1  
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>SGM Doors and Trim, LLC</b> <b>14625 Minetta Street, Bldg B</b> <b>Houston, TX 77035</b>	<b>Plastpro's 60 Minute Positive Pressure</b> <b>Fire Door Assemblies w/Hose Stream</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 60 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 6'8"</b>  <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)(2012)/UL 10C (2009)/</b> <b>CAN4 S104 (1985)/</b> <b>CAN/ULC S104 (2010)</b>	<b>60 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B - Additional Edge Sealing</b> <b>System Required</b>

TEST REPORT
<b>Intertek Test Report No: 3175675MID-004, 3196317MID-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122