

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015264
DATE: 04/28/2021
CERTIFICATION PROGRAM: Fire
COMPANY: SGM Door
CODE: 2743-1
EXPIRATION DATE: 04/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SGM Doors and Trim, LLC 14625 Minetta Street, Bldg B Houston, TX 77035 | "ABS 20-Minute" Routed Particleboard Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20-Minute Locations 1/2" Minimum Latch Throw Single Swing Only 20-Minute Single Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|
| NFPA 252 (2012) UL 10C (2009) | 20 Minute-Positive Pressure Without Hose Stream Category B - Additional Edge-Sealing System Required |

| TEST REPORT |
|----------------------------------------------------------------------------------------|
| Intertek Test Report No: 3107376COQ-004, 3169105, 3043898, 102245905, 104375792 |

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122