

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015270-R1
DATE: 05/10/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	<p style="text-align: center;">Series "6000"</p> <p style="text-align: center;">Vinyl Single Hung Window</p> <p style="text-align: center;">Configuration: O/X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.060" Eastman Chemical PVB Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1346mm(53") H-1880mm(74") Vent: W-1270mm(50") H-927mm(36.5") DLO: W-1245mm(49") H-1111mm(43.75")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E2395-18	<p style="text-align: center;">Class LC-PG60 1346 x 1880 (53 x 74)-H</p> <p style="text-align: center;">Design Pressure: ±2880 Pa (60 psf)</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf)</p> <p style="text-align: center;">Window Performance Level: L5</p>

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 210-4195-03A/NCTL 210-4195-03/NCTL-210-4214-4/W-1994
Expiration Date: October 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com