

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015280
DATE: 06/02/2021
CERTIFICATION PROGRAM: Structural
COMPANY: KHPP Windows
CODE: 1954-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
KHPP Windows and Doors 1136 Industrial Park Road Vandergrift, PA 15690	Series "KHPP Door PW 16 x 96 LC90" Vinyl Side Lite (New Construction) Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-406mm(16") H-2438mm (96") DLO: W-298mm(11.75") H-2330mm (91.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG90 406 x 2438 (16 x 96)-SLT Design Pressure: ± 4320 Pa (± 90 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek, PLC
Report No: D1113.04-501-44
Expiration Date: May 31, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122