

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015284  
DATE: 06/02/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: KHPP Windows  
CODE: 1954-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>KHPP Windows and Doors</b> <b>1136 Industrial Park Road</b> <b>Vandergrift, PA 15690</b>	<b>Series "KHPP Sliding Door</b> <b>96 x 96 R40"</b> <b>Vinyl Sliding Glass Door</b> <b>(New Construction &amp; Replacement)</b>  Configuration: OX Glazing: Insulating Glass (Tempered)  Frame: W-2438mm(96")      H-2438mm (96") Panel: W-1219mm(48")      H-2362mm (93") DLO: W-1022mm(40.25")      H-2165mm (85.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG20 2438 x 2438 (96 x 96)-SD</b> <b>Design Pressure: ±960 Pa (±20 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b>

Product Tested By: Intertek, PLC  
Report No: D0979.05-501-44  
Expiration Date: May 31, 2025

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122