

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015285
DATE: 06/02/2021
CERTIFICATION PROGRAM: Structural
COMPANY: KHPP Windows
CODE: 1954-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
KHPP Windows and Doors 1136 Industrial Park Road Vandergrift, PA 15690	Series "KHPP Impact 96 x 96 Impact AWS" Impact Rated Vinyl Sliding Glass Door (New Construction & Replacement) Configuration: XO Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090"PVB by Dupont SGP Interlayer/ 1/8" Annealed Glass Frame: W-2438mm(96") H-2438mm (96") Panel: W-1219mm(48") H-2362mm (93") DLO: W-1022mm(40.25") H-2162mm (85.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-11 ASTM E1886-05 ASTM E1996-12 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-8	Class LC-PG50 2438 x 2438 (96 x 96)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3 Wind Zone 3-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: F9932.07-501-44/F9932.08-501-44/F9932.01-501-44
Expiration Date: May 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over the signature line.

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122