

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015287
DATE: 06/10/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Doorscapes
CODE: 1834-1
EXPIRATION DATE: 06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc. 11833 Cutten Road, Suite 200 Houston, TX 77066	Jeld Wen 45-60 Minute Profiled Core Side-Hinged Door w/Universal or Universal HD Core Manufacturer Specific Fire Doors for Single & Double Swing Installation in 45-60 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only (Double Egress Not Allowed) Single Maximum Size: 3'6" x 7'0" Single Maximum Size: 3'0" x 8'0" Double Maximum Size: 7'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(c) (2009/2016) CAN/ULC-S104 (2015) NFPA 252 (2012)	45-60 Minute-Positive Pressure w/Hose Stream Category A Door-No Additional Edge Seal Required For Use in 16 & 18 Gauge Steel Frames (or may also be installed in Category C or Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: G103003006MID-008, WHI-495-1314

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122