NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015292

DATE: 06/10/2021

CERTIFICATION PROGRAM: <u>F</u>

PROGRAM: <u>Fire</u>
COMPANY: Doorses

CODE:

Doorscapes 1834-1

EXPIRATION DATE:

06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc.	Jeld Wen Premium 20 Minute Neutral
11833 Cutten Road, Suite 200	Pressure Fiberglass Side-Hinged Door
Houston, TX 77066	Assemblies
	Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing and Pairs Allowed
	Single Swing Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"
	Pairs Maximum Size: 6'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2008/2009) CAN/ULC S104 (2010)	20 Minute-Neutral Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT

Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001

Administrator's Signature:

Shi

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122