

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015295
DATE: 06/10/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Doorscapes
CODE: 1834-1
EXPIRATION DATE: 06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc. 11833 Cutten Road, Suite 200 Houston, TX 77066	20-Minute Aurora Composite Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999/2008/2012) UL 10C (2001/2009) UL 10B (1997/2009) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010)	20 Minute-Positive Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 100854038COQ-006

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122