

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015302
DATE: 06/10/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Doorscapes
CODE: 1834-1
EXPIRATION DATE: 06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc. 11833 Cutten Road, Suite 200 Houston, TX 77066	20-Minute Composite Wood Fire Door (Particleboard, Agristrand, Agri-Fiber or 22 pcf LDF Core) Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 4'0" x 10'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) UL 10C (2009/2015/2016) UL 10B (2009/2015) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010/2015)	20 Minute-Neutral/Positive Pressure With Hose Stream Category B - Additional Edge-Sealing System Required Category A - No additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 3125646COQ-004

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122