

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015304
DATE: 06/10/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Doorscapes
CODE: 1834-1
EXPIRATION DATE: 06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc. 11833 Cutten Road, Suite 200 Houston, TX 77066	"Madison/Monroe/Craftsman/Birkdale" Molded Panel Composite Fire Doors Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-11/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) UL 10C (2009/2015/2016) UL 10B (2009/2015) CAN/ULC S104 (2015)	20 Minute-Positive or Neutral Pressure With Hose Stream Category B - Additional Edge-Sealing System Required

TEST REPORT
Intertek Test Report No: 2192291COQ-005, 101070204COQ-001B Intertek EEV No: 100921055COQ-001, 103667744MID-001, 104106427MID-001, 1029627719MID-001

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122