

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015307
DATE: 06/16/2021
CERTIFICATION PROGRAM: Fire
COMPANY: Doorscapes
CODE: 1834-1
EXPIRATION DATE: 06/30/2025

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doorscapes, Inc. 11833 Cutten Road, Suite 200 Houston, TX 77066	PlastPro 60 Minute Positive Pressure Fire Door Assemblies w/Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 60 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012)/UL 10C (2009)/ CAN4 S104 (1985)/ CAN/ULC S104 (2010)	60 Minute-Positive Pressure With Hose Stream Category B - Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 3175675MID-004, 3196317MID-001

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122