

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015310.01-R2  
**DATE:** 06/23/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wood On  
**CODE:** 1332-1  
**REVISION DATE:** 04/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wood On LLC dba MW Millworks</b> <b>7225 Peppermill Parkway</b> <b>North Charleston, SC 29418</b>	<b>Series "Wood Entrance Door" Glazed</b> <b>Outswing Side-Hinged Door Assembly</b> <b>w/Transom &amp; Sidelites</b>  Configuration: O/OXXO Glazing: Monolithic - 1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass or IG - 1/4" Tempered Glass/1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass  Frame: W-3874mm(152.5") H-3429mm(135") Panel: W-1083mm(42.63") H-2540mm(100") DLO: W-3791mm(149.25") H-737mm(29")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b> <b>(Structural Only)</b> <b>TAS 201/203-94</b>	<b>Design Pressure: ±2633 Pa (±55 psf)</b> <b>Water Penetration Resistance Test Pressure: 129 Pa (2.7 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Fenestration Testing Laboratory  
Report No: 10438  
Expiration Date: May 31, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023