

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015310.01  
**DATE:** 06/23/2021  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wood On  
**CODE:** 1332-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wood On LLC dba MW Millworks</b> <b>7225 Peppermill Parkway</b> <b>North Charleston, SC 29418</b>	<b>Series "Wood Entrance Door" Glazed</b> <b>Outswing Side-Hinged Door Assembly</b> <b>w/Transom &amp; Sidelites</b>  Configuration: O/OXXO Glazing: Monolithic - 1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass or IG - 1/4" Tempered Glass/1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass  Frame: W-3874mm(152.5") H-3429mm(135") Panel: W-1083mm(42.63") H-2540mm(100") DLO: W-3791mm(149.25") H-737mm(29")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b> <b>(Structural Only)</b> <b>TAS 201/203-94</b>	<b>Design Pressure: ±2633 Pa (±55 psf)</b> <b>Water Penetration Resistance Test Pressure: 129 Pa (2.7 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Fenestration Testing Laboratory  
Report No: 10438  
Expiration Date: May 31, 2025

A handwritten signature in black ink, appearing to be 'S.M.', is written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122