

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015310.02-R2
DATE: 06/23/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Wood On
CODE: 1332-1
REVISION DATE: 04/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wood On LLC dba MW Millworks 7225 Peppermill Parkway North Charleston, SC 29418	Series "Wood Entrance Door" Glazed Outswing Side-Hinged Door Assembly w/Transom, Sidelites & Slide Bolts Engaged Configuration: O/OXXO Glazing: Monolithic - 1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass or IG - 1/4" Tempered Glass/1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass Frame: W-3874mm(152.5") H-3429mm(135") Panel: W-1083mm(42.63") H-2540mm(100") DLO: W-3791mm(149.25") H-737mm(29")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2633 Pa (±55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Large Missile Impact Rated

Product Tested By: Fenestration Testing Laboratory
Report No: 10438
Expiration Date: May 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023