

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015310.02
DATE: 06/23/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Wood On
CODE: 1332-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wood On LLC dba MW Millworks 7225 Peppermill Parkway North Charleston, SC 29418	Series "Wood Entrance Door" Glazed Outswing Side-Hinged Door Assembly w/Transom, Sidelites & Slide Bolts Engaged Configuration: O/OXXO Glazing: Monolithic - 1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass or IG - 1/4" Tempered Glass/1/4" Annealed Glass/0.090" Kuraray SG/1/4" Anealed Glass Frame: W-3874mm(152.5") H-3429mm(135") Panel: W-1083mm(42.63") H-2540mm(100") DLO: W-3791mm(149.25") H-737mm(29")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2633 Pa (±55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Large Missile Impact Rated

Product Tested By: Fenestration Testing Laboratory
Report No: 10438
Expiration Date: May 31, 2025

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122