

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015353.01  
DATE: 08/03/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: Kudzu  
CODE: 2118-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kudzu Millwork, Inc.</b> <b>1201 Echols Drive West</b> <b>Fort Payne, AL 35968</b>	<b>Series "1400"</b> <b>Vinyl Fixed Picture Window</b>  Configuration: O Glazing: Insulated Glass (Annealed)  Frame: W-1219mm(48") H-1219mm(48") DLO: W-1095mm(43.13") H-1095mm(43.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG90 1219 x 1219 (48 x 48)-FW</b> <b>Design Pressure: ±4320 Pa (±90 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC  
Report No: L5006.02-901-44  
Expiration Date: October 31, 2024

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122