

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015366-R1
DATE: 08/09/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Boise Cascade
CODE: 1879-1
REVISION DATE: 01/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Boise Cascade, LLC 8260 Armstrong Road Milton, FL 32583	Series "S210" Glazed 6-Panel Fiberglass Inswing Side-Hinged Entry Door (w/BTS Doorlite Frame) Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-939mm(37") H-2095mm(82.5") Panel: W-911mm(35.88") H-2012mm(79.25") DLO: W-527mm(20.75") H-882mm(34.75") STP: +1819 Pa (+ 38 psf) -1819 Pa (-38 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1702.02-95 Federal Manufactured Home Construction & Safety Standard 3280.305	Manufactured Housing-Passed Wind Zone II

Product Tested By: Intertek, PLC
Report No: L8921.01-201-44
Expiration Date: **February 28, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com